

UKCA Certificate of Constancy of Performance

This is to certify that:

Witt and Son UK Holdings Ltd
Witt House
3 Shelf Mills
Shelf
Halifax
HX3 7BJ
United Kingdom

Holds Certificate Number:

0086 CPR 777615

In respect of:

BS EN 12101-3:2015 - Powered smoke and heat control ventilators

In compliance with the Regulation (UK) Statutory Instrument 2019 No 465 of the United Kingdom Parliament (Construction Products (Amendment etc.) (EU Exit) Regulations or CPR), this certificate applies to the above construction product. This certificate attests that all the provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the above standard(s) under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product. This certificate was first issued on the date below and will remain valid as long as neither the designated standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.

For and on behalf of BSI, an Approved Body for the above Regulation (Approved Body Number 0086):

Shahm Barhom, Group Product Certification Director

First Issued: 2022-12-01
Latest Issue: 2024-10-04

Effective Date: 2024-10-04



UKCA Certificate of Constancy of Performance

No. 0086 CPR 777615

BS EN 12101-3:2003 – Powered smoke and heat control ventilators

Smoke Extract Fan Range B Type blades BSRIA report 58866/4 refers.	2 Pole Models			
	315/2/110/5B	315/2/160/10B	355/2/110/5B	355/2/160/5B
	355/2/160/10B	400/2/110/5B	400/2/160/5B	400/2/160/10B
	450/2/110/5B	450/2/160/5B	450/2/160/10B	500/2/110/5B
	500/2/160/5B	500/2/160/10B	500/2/230/6B	500/2/230/12B
	560/2/160/5B	560/2/160/10B	560/2/230/6B	560(570)/2/230/12B
	630/2/230/6B	630/2/230/12B		
	4 Pole Models			
	315/4/110/5B	315/4/160/10B	355/4/110/5B	355/4/160/5B
	355/4/160/10B	400/4/110/5B	400/4/160/5B	400/4/160/10B
	450/4/110/5B	450/4/160/5B	450/4/160/10B	500/4/110/5B
	500/4/160/5B	500/4/160/10B	500/4/230/6B	500/4/230/12B
	560/4/160/5B	560/4/160/10B	560/4/230/6B	560/4/230/12B
	630/4/160/5B	630/4/160/10B	630/4/230/6B	630/4/230/12B
	710/4/230/6B	710/4/230/12B		
	6 Pole Models			
	400/6/110/5B	400/6/160/5B	400/6/160/10B	450/6/110/5B
	450/6/160/5B	450/6/160/10B	500/6/110/5B	500/6/160/5B
	500/6/160/10B	500/6/230/6B	500/6/230/12B	560/6/160/5B
	560/6/160/10B	560/6/230/6B	560/6/230/12B	630/6/160/5B
	630/6/160/10B	630/6/230/6B	630/6/230/12B	710/6/230/6B
	710/6/230/12B			
	Resistance to Fire class	F300 (tested to 300°C, 120 minutes)		
Motor rating	Class F / Class H			
Ancillaries	Flexible connector AFG10/10			
	Inlet cone			
	Fan mounting feet			
	Flexible connector SCF/3			
	Weg Motors - Thermistors			

First Issued: 2022-12-01
 Latest Issue: 2024-10-04

Effective Date: 2024-10-04

Page: 2 of 4

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
 To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
 A member of BSI Group of Companies.

UKCA Certificate of Constancy of Performance

No. 0086 CPR 777615

BS EN 12101-3:2003 – Powered smoke and heat control ventilators

Smoke Extract Fan Range C Type blades BSRIA reports 58866/3 & 51905/1 refer.	4 Pole models				
	800/4/4C	800/4/8C	800/4/12C	800/4/16C	900/4/4C
	900/4/8C	900/4/12C	900/4/16C	1000/4/4C	1000/4/8C
	1000/4/12C	1000/4/16C	1120/4/4C	1120/4/8C	1120/4/12C
	1120/4/16C	1250/4/4C	1250/4/8C	1250/4/12C	1250/4/16C
	6 Pole models				
	800/6/4C	800/6/8C	800/6/12C	800/6/16C	
	900/6/4C	900/6/8C	900/6/12C	900/6/16C	
	1000/6/4C	1000/6/8C	1000/6/12C	1000/6/16C	
	1120/6/4C	1120/6/8C	1120/6/12C	1120/6/16C	
1250/6/4C	1250/6/8C	1250/6/12C	1250/6/16C		
1400/6/4C	1400/6/8C	1400/6/12C	1400/6/16C		
Response Delay	N/A				
Resistance to Fire class	F300 (tested to 300°C, 120 minutes)				
Motor rating	Class F / Class H				
Ancillaries	Flexible connector				
	Inlet cone				
	Fan mounting feet				

First Issued: 2022-12-01
 Latest Issue: 2024-10-04

Effective Date: 2024-10-04

Page: 3 of 4

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
 To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
 A member of BSI Group of Companies.

UKCA Certificate of Constancy of Performance

No. 0086 CPR 777615

BS EN 12101-3:2003 – Powered smoke and heat control ventilators

Axial Fans	Model references		
	P-X8JL5/315/GT/3	P-NR12JT5/400/GR/4	P-N8L5/400/GT/4
Response Delay	N/A		
Resistance to Fire Class	F300 (120 mins), F300 (60 mins) F200 (120 mins)		
Motor Rating	Class H		
Ancillaries	Silencers, protective grids, guide vanes, isolator and terminal boxes.		
Test report number: 3547/162/07-C5.1 and C5.2 3083/116/12-C5.1 and C5.2			



First Issued: 2022-12-01
Latest Issue: 2024-10-04

Effective Date: 2024-10-04

Page: 4 of 4

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.